

**CERTIFICATION REF.**  
CP041-DCM-A1206.22

Issuing date: 09/12/2009

**Master S.r.l., declares what follows:**

The item A1206.22 on window dimensions

Height	Width
Minimum-Maximum (mm)	Maximum (mm)
1600-1800	1800

With the following setting:

Opening angle	Weight
20°	120 Kg
30°	110 Kg

**has passed the test according the norm UNI EN 13126-6:2008**

**VARIABLE GEOMETRY STAY HINGE (WITH OR WITHOUT FRICTION SYSTEM)**


**Test carried out on:**

Pneumatic machinery

**According the norms:**

UNI EN 13126-1:2006  
UNI CEN/TS 13126-5 :2005  
UNI EN 13126-6:2009

Category of Use	Durability	Mass	Fire Resistance	Safety in Use	Corrosion Resistance	Security	Application	Test Size
-	5	120	0	1	4	-	11	1800x1800

**MASTER s.r.l.**  
L'Amministratore Unico  
**MARIA LUGIA LACATENA**  


**Maria Luigia Lacatena**  
Amministratore Unico MASTER srl

La presente dichiarazione è basata su specifiche di prova stabilite internamente da MASTER srl  
MASTER srl si riserva il diritto di variare le caratteristiche tecniche dei suoi prodotti, senza preavviso ed in ogni momento.  
Tutti i diritti sono riservati. E' fatto divieto di qualunque riproduzione parziale o totale dei presenti documenti.