

DOCUMENT CODE
CP222-DLA-1205.3 and 1206.20

Master S.r.l., declares that:

Limiter arm 1205.3 with 1206.20

Test mass 120 Kg

Test dimensions L x H

1600x1600 (mm)

Passed test according to UNI EN 13126-5 e UNI EN 13126-6:

variable geometry stay hinges (with or without a friction stay)
and
devices that restrict the opening of windows
25.000 cycles

Classification of limiter arm :

| Category of use | Durability | Mass | Fire resistance | Safety in use | Corrosion | Security | Application | Test size |
|-----------------|------------|------|-----------------|---------------|-----------|----------|-------------|-----------|
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| - | 5 | 120 | 0 | 1 | 5 | 0 | 2 | 1600/1600 |

Date of issue: 05/12/2013

Maria Luigia Lacatena
Amministratore Unico MASTER srl

La presente dichiarazione è basata su specifiche di prova stabilite internamente da MASTER srl
MASTER srl si riserva il diritto di variare le caratteristiche tecniche dei suoi prodotti, senza preavviso ed in ogni momento.
Tutti i diritti sono riservati. E' fatto divieto di qualunque riproduzione parziale o totale dei presenti documenti.