

**DOCUMENT CODE**  
**CP249-DLA-1203A.6**



**Master S.r.l., declares that:**

Restrictor stays with key cod. 1203A.6

Test mass 108 Kg

Test dimensions L x H (1100x1100) mm

**Passed test according to:**

**EN 13126-5:2011** : Building hardware, fitting for windows and door height windows (Device that restrict the opening of windows).

**EN 13049:2003** : Windows, soft and heavy body impact.

**EN 1670:2007** : Building hardware, Corrosion resistance

Impact test n°270 of 16.04.2014, executed by “**TecnoProve s.r.l.**” Technological Laboratory, classify the building hardware as follows:

**Classification:**

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion	Security	Application	Test size
1	2	3	4	5*	6	7	8**	9
-	5	108	0	2/1	5	-	5/4	1100/1100

\*(fifth digit): 2/1 security requirements. Height of fall 200mm.

\*\* (eighth digit): 5/4 safety limiter (max. aperture 100mm)

Date of issue: 06/05/2014

Lab Manager

Dott. Eng. Enrico Maggio