



Master S.r.l., declares that:

Restrictor stays with key cod. 1203A.10

Test mass 115 Kg

Test dimensions L x H (1500x1500) mm

Passed test according to:

EN 13126-5:2011 : Building hardware, fitting for windows and door height windows (Device that restrict the opening of windows).

EN 13049:2003 : Windows, soft and heavy body impact.

EN 1670:2007 : Building hardware, Corrosion resistance

Impact test n°270 of 16.04.2014, executed by “**TecnoProve s.r.l.**” Technological Laboratory, classify the building hardware as follows:

Classification:

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion	Security	Application	Test size
1	2	3	4	5*	6	7	8**	9
-	5	115	0	2/1	5	-	5/4	1500/1500

*(fifth digit): 2/1 security requirements. Height of fall 200mm.

** (eighth digit): 5/4 safety limiter (max. aperture 100mm)

Date of issue: 06/05/2014

Lab Manager

Dott. Eng. Enrico Maggio